

Joint Office

enquiries@gasgovernance.co.uk

12th May 2022

Dear Sir or Madam,

Re: UNC 0771S Removal of the absolute requirement to include a Remotely Operable Valve (ROV) Installation for all new NTS Entry connections

Thank you for the opportunity to provide representation on the above noted Modification/Change Proposal. Please find below Northern Gas Network's (NGN) comments in respect of this change.

NGN offers comments only in relation to this Modification Proposal.

We would like to highlight that this modification is only applicable to sites directly connected to NTS, and therefore DN connects will still be subject to a ROV where applicable, including where stated as part of a Network Entry Agreement (NEA).

We believe that the legal text satisfies this, but still wanted to draw it to the attention of industry to aid in avoiding confusion.


I hope these comments will be of assistance and please contact me should you require any further information in respect of this response.

Yours sincerely,

Tracey Saunders (via email)
Market Services Manager
Mobile: 07580 215 743

Smell gas?

Call the National Gas Emergency
Service on 0800 111 999

 1100 Century Way
Thorpe Park Business Park
Colton, Leeds LS15 8TU

 0113 397 5300
 northerngasnetworks.co.uk

**we are
the network**