



Preliminary Safety Monitor Requirements 2021/22

28th May 2021

nationalgrid

Safety Monitor Requirements

Executive Summary

Based on a forecast of 395mcm of Non Storage Supply (NSS) on a Cold Day, the Preliminary Storage Space requirement for Winter 2020/21 is 0 GWh, with a deliverability of 0 GWh/d. The NSS forecast remains unchanged from the 2020/21 figure used in September 2020.

Introduction

This document sets out the preliminary 'Safety Monitor' for the 2021/22 winter, pursuant to National Grid's obligations under the Uniform Network Code Section Q.

The preliminary safety monitor provided in this note uses our initial 2020/21 demand forecasts and our latest supply analysis produced, as mentioned above. Our demand forecasts are yet to be completed for 2021/22 and some elements of our supply analysis are to be finalised. These will potentially lead to changes in the final monitor published in September.

It is our responsibility to keep the safety monitor under review (both ahead of and throughout the winter) and to make adjustments, if it is appropriate to do so, on the basis of the latest information available. We will continue to provide within winter feedback to industry regarding supply assumptions and any resulting changes to safety monitors by means of monthly updates via Operational Forum meetings and information on our web site. In doing so, we must recognise that the purpose of the safety monitor is to ensure an adequate pressure can be maintained in the system at all times and thereby protect public safety.

Background

The Uniform Network Code (UNC) requires us to publish the safety monitor and to provide regular reporting of actual storage stock levels for comparison with the monitor. As the name suggests, the focus of the safety monitor is public safety rather than security of supply. It provides a trigger mechanism for taking direct action to avoid a potential gas supply emergency (as defined in the Gas Safety (Management) Regulations).

Methodology

There continues to be two main steps in the assessment of the safety monitor:

- The calculation of the total storage requirement at the start of the winter
- The assessment of the way in which this initial requirement declines as the winter progresses, known as the winter profile. This second step also includes an assessment of how the total storage deliverability requirement reduces as the winter progresses.

This note only covers the first step, by providing a preliminary assessment of the safety monitor space requirement. The safety monitor requirement is highly dependent on the assumptions made regarding the aggregate level of non-storage supply (NSS). We will be consulting on the likely non storage supplies we may see this coming winter. Once the winter consultation process is complete, we will publish the final safety monitor in September, including the monitor storage space requirement and the deliverability requirement.

Safety Monitor Calculation Process

The concept behind the safety monitor is to ensure that sufficient gas is held in storage to support those gas consumers whose premises cannot be physically and verifiably isolated from the gas network within a reasonable time period. To achieve this all gas consumers are categorised into one of two groups:

- Protected by Monitor - Gas is held in storage to facilitate continuity of supply to these consumers even in a 1 in 50 winter
- Protected by Isolation – Network safety would be maintained if necessary by physically isolating these customers from the network

The categorisation into these groups is summarised in the table below:

Table 1: End Consumer Categorisation for Safety Monitors

Protected by Isolation - Sites which can be safely isolated from the network	Protected by Monitor - Sites which require protection under the safety monitor
NTS Power	Priority ¹ DM ²
NTS Industrial	NDM
DM (excluding priority customers)	Exports to Ireland for NDM
Exports to Ireland for DM	

The safety monitor storage requirements comprise two elements:

- **Supply-demand:** Storage required to support 'protected by monitor' loads, assessed using a severe (1 in 50) winter load duration curve and assumed supply levels;

¹ Currently, priority daily metered (DM) loads represent less than 2% of protected by monitor demands.

² Daily Metered

- **Isolation:** Storage required during the process of demand reduction, effectively to support 'protected by isolation' loads during the period in which these loads are isolated from the system.

Supply

There continues to be uncertainty regarding the aggregate level of non-storage supplies especially the individual components of these supplies. LNG and interconnector imports continue to be elements with most uncertainty. The focus of the safety monitors is public safety and hence, it is prudent to ensure that the assumed level of NSS will be available throughout the winter, notably at times of high demand.

Our final view of supplies for next winter will be detailed in our Winter Outlook Report document to be published in October. Our NSS assumptions can be summarized as follows:

- Rather than use our forecasts for NSS for winter 2021/22, our NSS assumption is based upon a NSS versus demand relationship based upon a weighted rolling average of the last five years of historic data.
- Analysis of previous winters' data shows that assuming an availability of 98% captures typically 98% of all data points, with those that are still below often the result of short term supply losses.

Table 2 shows the anticipated availability of storage capacity in winter 2020/21.

Table 2 - Storage

	Space (GWh)	Deliverability (GWh/d)
Medium (MRS) ³	17,548	1,041
Long (Rough)	0	0
Total	16,990	1,126

³ Excludes Holehouse Farm. These numbers are preliminary and will potentially change by October 2021.

Demand

The demand background used for the analysis in this section uses our demand forecasts for 2020/21 that were produced in July 2020: the final safety monitor will be based upon our final 2021 demand forecasts for 2021/22.

Preliminary Safety Monitor Space Requirement

Table 3 shows the total safety monitor space requirement on the basis of the supply and demand assumptions outlined above. The 2021/22 space requirement is 0 GWh.

Table 3 – Total Preliminary Safety Monitor Space Requirement

	Total storage capacity (GWh)	Space requirement (GWh)	Space requirement %
Total	17,548	0	0%

Table 4 gives a high level indication of the potential supply demand balance on the highest demand day of a 1 in 50 severe winter.

It shows the protected by isolation demand supported under the safety monitor on day 1 of the 1 in 50 winter. It also shows total supplies available for the same day. It should be noted that there is additional deliverability over and above that required to meet NDM and BEIS defined priority load demand on the day. These numbers are based on Future Energy Scenarios (FES) 2020 as FES 2021 numbers have not been finalised yet, therefore these numbers in Table 4 are likely to change.

Table 4 – Preliminary Peak NDM & Priority Demand and Peak Day Supply

Demand	GWh/d
Peak NDM & Priority Demand (A)	3,705
Peak Supplies	
NSS	4,344
Storage	0
Total Supplies (B)	4,344
Supply Surplus (B) – (A)	639

General Queries

If you have any queries or questions regarding the information contained within this document, please contact:

Access Planning Team

Gas System Operator

National Grid

National Grid House

Gallows Hill

Warwick

CV34 6DA

NTSuccessplanning@nationalgrid.com

Tel: 01926 655958

We would welcome any feedback from you in relation to the Safety Monitor requirements or the way in which this information is provided. If you would like to provide feedback please contact us via email at:

NTSuccessplanning@nationalgrid.com

National Grid plc
National Grid House,
Warwick Technology Park,
Gallows Hill, Warwick.
CV34 6DA United Kingdom
Registered in England and Wales
No. 4031152

nationalgrid.com