

FAO: All Users for information

**Notice of Amendment of Network Entry Provisions between:
National Gas Transmission and Shell U.K. Limited**

**Amendment to the Carbon Dioxide Limit at the Shell St Fergus NTS System Entry Point
27/11/2024**

This notice:

- **Is given by National Gas Transmission for the attention of all Users.**
- **Is given under the Uniform Network Code, Transportation Principal Document, Section I, paragraph 2.2.6(b).**

In accordance with UNC TPD section I2.2.3(b), any Delivery Facility Operator may access a carbon dioxide limit of up to 2.5mol%. National Gas Transmission hereby gives notice of an increase to the carbon dioxide limit from 2.0mol% to 2.5mol% for the St Fergus Shell natural gas terminal operated by Shell U.K. Limited.

Yours faithfully,

Natalie Ellard

*Natalie Ellard
Customer Lifecycle Manager
National Gas Transmission*

Email: Natalie.ellard@nationalgas.com